



कार्यालय अधिशासी अभियन्ता

खण्ड कार्यालय, उत्तर प्रदेश जल निगम (ग्रामीण),
220, सिविल लाइन्स, मेरठ- 250001
e-mail: ee_ist_upjn_mmr@yahoo.co.in

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Vinay Kumar Nayak Junior Engineer Division office U.P. Jal Nigam (Rural), Meerut inspected the Vidya Global School, Baghpat Road, Meerut on 21.12.2024 and on the basis of Water Test Report (Attached) Bearing No.502 Dated 26.12.2024 of District Level Water Analysis Laboratory UP Jal Nigam (Rural), Meerut Certified that the Vidya Global School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UT Govt.

The above valid for a period of 1 Year.

Singnature with Seal :
Name & Address of the office/Department
EXECUTIVE ENGINEER DIV. OFFICE,
UTTAR PRADESH JAL NIGAM (RURAL),
MEERUT.

Assistant Engineer
Divisional Office
U.P. Jal Nigam (Rural)
Meerut

To,

Vidya Global School
Baghpat Road, Meerut.

Note:- The above certificate based on the sample test result.

remesh

Principal
Vidya Global School
Vidya Knowledge Park
Baghpat Road, Meerut-250002

✓ R. K. Singh
Managing Director
Vidya Global School
Vidya Knowledge Park, Baghpat Road
Meerut-250002



District Level Water Analysis Laboratory Uttar Pradesh Jal Nigam, (Rural), Meerut (UP).

F. Issue No:02

F. Issue Date:

18.04.2022

Revision No:00

Test Report

URL	N/A		
Letter No.	VGS/2024/07	Date	6/12/24
Customer Name and Address	VIDYA GLOBAL SCHOOL BAGHPAT ROAD, MEERUT		
Sampling Method ISO 17614 (Part - 1):2021			
Report No.	502	Report Issue Date:	26/12/2024
Sample Description :-		Liquid transparent and colourless liquid received at ambient condition.	
Basic Details of Sample:-			
District	MEERUT	Gram Panchayat	PANCHLI KHURD
Block	JANI	Habitation	PANCHLI KHURD
Village	PANCHLI KHURD	Location	VIDYA GLOBAL SCHOOL BAGHPAT ROAD, MEERUT
Water Source	TAP WATER	Sample ID	M/24/12/P502
Depositor	AARYAN TOMAR	Date of sampling.	21.12.2024
Sample Collector	AARYAN TOMAR	Receiving Date	21.12.2024
Discipline Sample	Chemical	Analysis Start Date	23.12.2024
Packaging Type	Plastic bottle	Analysis Completion Date	23.12.2024
Group	Water	Quantity	1 Liter
Temperature (25± 3)°C	22°C	Humidity (50%± 15%)	52%

Technical Data of Analysis

SR. NO.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH @25°C	7.89	6.5-8.5	6.5-8.5	IS 3025 (Part II): 2017 (Electrometric Method)
2	Turbidity (NTU)	3.18	1.00	5.00	IS 3025 (Part 10): 12017 (Nephelometer Method)
3	TDS, mg/l	499	500	2000	IS 3025 (Part 16): 2017 (Gravimetric Method)
4	Chloride (as Cl), mg/l	26	250	1000	IS 3025 (Part 32): 2019 (Titration Method)
5	Total Alkalinity (as Na ₂ CO ₃), mg/l	180	200	600	IS 3025 (Part 23): 2019 (Titration Method)
6	Total Hardness (as CaCO ₃), mg/l	192	200	600	IS 3025 (Part 21): 2019 (Titration Method)
7	Calcium (as Ca), mg/l	38.4	75	200	IS 3025 (Part 40): 2019
8	Magnesium (as Mg), mg/l	23.04	30	100	IS 3025 (Part 46): 2019
9	Sulphate (as SO ₄), mg/l	19.91	200	400	APHA 23 RD Ed 2017, 4500-SO ₄ (E. Turbidimetric Method)
10	Nitrate (as NO ₃), mg/l	11.62	45	No Relaxation	APHA 23 RD Ed 2017, 4500-NO ₃ (B. Ultraviolet Spectrophotometric Screening Method)
11	Fluoride (as F), mg/l	0.736	1.0	1.5	APHA 23 RD Ed 2017, 4500-F (C. Ion Selection Electrode Method)
12	Iron (as Fe), mg/l	0.12	1.0	No Relaxation	APHA 23 RD Ed 2017, 3500-Fe (B Phenanthroline Method)
13	Colour	-	5HU	15HU	APHA 23 RD Ed 2021 Colour Method (Platinum cobalt Visual Comparison):2017
14	Taste	Satisfactory	Qualitative	-	IS 3025 (Part 08): 2017
15	Odour	Satisfactory	Qualitative	-	IS 3025 (Part 05): 2018
16	Conductivity	-	<2500	No rel.	Standard Value as per WHO (2017)
17	Free residual chlorine	0.2	0.2	1	IS 3025 (Part 26)

1. Refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.

Chemist

Junior Engineer

Assistant Engineer

.....End Of Report.....

Principal
Vidya Global School
Vidya Knowledge Park
Baghpatt Road, Meerut-250002

Managing Director
Vidya Global School
Vidya Knowledge Park, Baghpatt Road, Meerut
Meerut-250002

Assistant Engineer
Divisional Office

UP. Jal Nigam (Rural,
Meerut